

**Vojenský technický ústav, s.p.**  
**branch VTÚPV**  
V. Nejedlého 691, 682 03 Vyškov, Czech Republic

**CERTIFICATE**  
**N° VTÚPV – 004 / 2013 / ZAHR**

**Applicant:** **CHANGHONG PLASTICS GROUP IMPERIAL PLASTICSCO., LTD**  
(4999 Express Way, Xinwu Economic Development Zone) Zhaoqiao  
Pioneer Park, Wuhu Machinery Industry Development Zone, Wuhu,  
Anhui, China

**Product:** **Insulated Male & Female Disconnectors**

**Model:** **FDD1.25-250, FDD2-250, FDD5.5-250, MDD1.25-250, MDD2-250,  
MDD5.5-250**

**Manufacturer:** **CHANGHONG PLASTICS GROUP IMPERIAL PLASTICS CO., LTD**  
(4999 Express Way, Xinwu Economic Development Zone) Zhaoqiao  
Pioneer Park, Wuhu Machinery Industry Development Zone, Wuhu,  
Anhui, China

**Rating and principal characteristics:** **Rating Current Max.: 10/15/24 A;**  
**Conductor Area: 0.5-1.5/1.5-2.5/4-6 mm<sup>2</sup>**  
**PVC Insulation**

Test results are described in the Test Reports No.:  
SCC(12)-203-60-LVD (tests made by China Ceprei (Sichuan) Laboratory)

The sample of tested product conforms with the requirements of the following standards  
harmonized with the LVD Directive No. 2006/95/EC

- EN 61210: 2010

This certificate is valid until: **08. 01. 2016**

After preparation of the necessary technical documentation as well as the conformity declaration, the  
required CE marking can be affixed on the product. Other relevant directives have to be observed.  
The CE mark shall appear according to this sample:

**CE**

Vyškov 08. 01. 2013

Tel./Fax: +420 517 303 603  
e-mail: milan.bezdek@vtusp.cz  
<http://www.vtusp.cz>

*M. Bezděk*  
**Milan Bezděk**  
Certification Head

